



## **Addendum No. #2**

### **RFP 18-03 Campus-Wide Access Control**

**AMEND THE FOLLOWING FOUND IN THE COLLEGE BID DOCUMENT, RFP 18-03:**

#### **Attachment F – Campus Door Schedule**

Changes made to Attachments to RFP 18-03:

1. All “keypad” wording changed to card reader on all attachments.
2. Added to Programmable/TOD to mean time of day.
3. Attachment #15 and I5A Bldg. B
  - a. Door # 101-1 removed card reader, just programmable/TOD
  - b. Door# 101-2 inserted card reader, programmable/TOD
4. Attachment #16 Bldg. A
  - a. Door#16 (outside door) added contact.
  - b. Additional telecom room, behind stage, up metal staircase added on map Attachment #16A

**Please adjust your Bid Response Form Attachment D “Addenda Acknowledgement,” note this Addendum (#2 18-03) and sign, when you submit your response to RFP 18-03.**

End of Addendum Number Two (2)

Deb J. Olson 1/11/2019