



### **Addendum No. #3**

**RFP 18-03 Campus-Wide Access Control**

**AMEND THE FOLLOWING FOUND IN THE COLLEGE BID DOCUMENT, RFP 18-03:**

#### **Attachment F – Campus Door Schedule, Attachment #1, Attachment #20 and Attachment #20A**

1. Attachment #1: The door schedule color key: The color Red should read: **Multi-tech Card Readers**  
"Not" Multi-tech Keypads/Readers
2. Attachment #20: Lake Placid Campus Add: Door #003-3 with Lock Function "Contact"
3. Attachment #20A: Door #003-3 added to map, identified in color "green"

**AND**

#### **Page 34 – 7. – Added Door 0003-3 and change total of Wireless Transmitters from 5 to 6**

7. Doors 0003-3, 116, 140, 141, 155, 158 Status Monitoring (According to Associated Layout): (Attachment #20b shows doors 155 & 158)
  - a. Provide and install (6) wireless Inovonics transmitters
  - b. Provide and install (6) recessed door contacts

**Please adjust your Bid Response Form Attachment D "Addenda Acknowledgement," note this Addendum (#3 18-03) and sign, when you submit your response to RFP 18-03.**

End of Addendum Number Three (3)

Deb J. Olson 1/17/2019